

3303.1 Listed

Temporary heating devices shall be *listed* and *labeled* in accordance with the [International Mechanical Code](#) or the [International Fuel Gas Code](#). Installation, maintenance and use of temporary heating devices shall be in accordance with the terms of the listing.

3303.5 Installation

Clearance to combustibles, tent included, from temporary heating devices shall be a minimum of 10 feet and maintained in accordance with the *labeled* equipment. When in operation, temporary heating devices shall be fixed in place and protected from damage, dislodgement or overturning in accordance with the manufacturer's instructions.

3303.6 Supervision

The use of temporary heating devices shall be supervised and maintained only by competent personnel.

Gas/Propane Pipe:

Gas pipe needs to be identified by either painting it yellow or ribbon wrap with tape labeled gas pipe.

Gas supply shut-offs need signage at location.

Gas/Propane Flexible Supply Lines:

Gas/propane supply lines shall be protected from foot/vehicle traffic directly on them and clearly marked as "gas".